

# Hydro-Flow Inc.

P.O. Box 3849, Central Point, OR 97502  
 (541)772-4453 Fax (541)773-3481  
 CCB #110565

## FLOW TEST REPORT

Job No: 1480

Prepared for:	Your Client			
Address:	Billing Address		Time:	8:48 AM
Site Address:	Site Address		Date:	10/26/93
Technician:			Pump Depth:	*111 ft
Pump Type:	Submersible	HP: 3/4	Well Depth:	**126 ft
Well Diameter:	6"		Static Level:	17 ft
Draw Down Level:	111 ft	3 in	Total Draw Down:	94 ft
Recovery Level:	52 ft	10 in	Total Recovery:	58 ft
Total Gallons Flowed:	1469.1		Average GPM:	6.1
Test Type:	Flow Test		Meter No:	64199340
Comments:	*1. Pump Depth of 111 feet 3 inches per level probe in pump column. **2. Well depth is 126 feet per well log.			

TIME	WATER LEVEL	METER READING	GAL/15 min	GPM
8:48 AM	17 ft 3 in	106996.1		
9:03 AM	64 ft 3 in	107115.6	119.5	7.97
9:18 AM	79 ft 6 in	107230.0	114.4	7.63
9:33 AM	98 ft 3 in	107341.3	111.3	7.42
9:48 AM	111 ft 3 in	107447.0	105.7	7.05
10:03 AM	111 ft 3 in	107533.7	86.7	5.78
10:18 AM	111 ft 3 in	107619.9	86.2	5.75
10:33 AM	111 ft 3 in	107706.2	86.3	5.75
10:48 AM	111 ft 3 in	107791.0	84.8	5.65
11:03 AM	111 ft 3 in	107876.2	85.2	5.68
11:18 AM	111 ft 3 in	107960.9	84.7	5.65
11:33 AM	111 ft 3 in	108044.4	83.5	5.57
11:48 AM	111 ft 3 in	108129.4	85.0	5.67
12:03 PM	111 ft 3 in	108213.0	83.6	5.57
12:18 PM	111 ft 3 in	108297.2	84.2	5.61
12:33 PM	111 ft 3 in	108381.2	84.0	5.60
12:48 PM	111 ft 3 in	108465.2	84.0	5.60
1:03 PM	52 ft 10 in			

I certify that the above report is true and accurate statement of the results of the flow test of the well at Site Address

Conducted on 10/26/93

\_\_\_\_\_  
Authorized Signature